

Male Closing Plugs

PLG Series

CERTIFICATE



ECM 18 ATEX 3845 U

EX CODE

II 2G Ex db IIC Gb/II 2D Ex tb IIIC Db

DIRECTIVE

2014/34/EU

STANDARD

EN 60079-0/A11:2013, EN 60079-1:2014, EN 60529/A2:2013

INSTALLATION

zone 1 – 2 – 21 - 22

Code	Size (MM & NPT)	Dimensions		
		A	L	H2
	M			
PLG -1M	M20	25	15	21
PLG -2M	M25	32	15	21
PLG -3M	M32	36	15	21
PLG -4M	M40	45	15	21
PLG -5M	M50	55	15	21
PLG -6M	M63	70	15	21
PLG -7M	M75	80	15	21
PLG -8M	M90	100	15	21
	NPT			
Code	NPT	A	L	H2
PLG-1N	1/2"	25	17	23
PLG -2N	3/4"	30	17	23
PLG -3N	1"	36	19	25
PLG -4N	1 1/4"	45	19	25
PLG -5N	1 1/2"	55	19	25
PLG -6N	2"	70	19	25
PLG -7N	2 1/2"	80	25	31
PLG -8N	3"	95	25	31

